



ITEM	DESCRIPTION
A	3" FLG RESILIANIT SEATING G.V. WITH 2" SQ. NUT, CLOSE CLOCKWISE
B	SCREW FLANGE
C	3" BRONZE NIPPLE
D	TRACER WIRE FOR PVC PIPE ONLY, TW TYPE #10
E	3" BRONZE 90° ELL
F	3" BRONZE CLPG
G	3" BRONZE SCREW PLUG
H	3" BRONZE RISER (1 LENGTH TO PROPER HEIGHT)
I	C.I. CAP WITH 3" TAP
J	3" BRONZE PIPE
K	PIPE CLAMP
L	CENTERING BLOCK (7.5" DIA 1 LB POWDER COATED)

NOTES:

- FOR SIZE OF BLOW-OFF ON MAINS LARGER THAN 16", CONSULT DISTRICT ENGINEER.
- LOWER PORTION OF 3" PIPE AND G.V. TO BE BURIED IN CONCRETE THRUST BLOCK. DO NOT BURY BONNET OF G.V. WITH CONCRETE.
- TO BE USED ONLY AT THE DIRECTION OF DISTRICT ENGINEER.
- COAT VALVE WITH BITUMINOUS PAINT, SEE SPECIFICATIONS.
- RECYCLED WATER BLOW OFF ASSEMBLIES SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.
- ALL BOLTS SHALL BE STAINLESS STEEL TYPE 304, OR APPROVED EQUAL. ANTI-SEIZE LUBRICANT SHALL BE APPLIED TO BOLT THREADS.

Dublin San Ramon Services District

REVISION DATE
NOV 2011

3" BLOW-OFF ASSEMBLY AT DEAD END
10" AND 12"

REVISED BY
BCD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-10