



ITEM	DESCRIPTION
A	3" FLG G.V. WITH 2" SQ. NUT, CLOSE CLOCKWISE
B	SCREW FLANGE
C	3" BRONZE NIPPLE
D	3" BRONZE 90° ELL
E	3" BRONZE CLPG
F	3" BRONZE SCREW PLUG
G	3" BRONZE RISER (1 LENGTH TO PROPER HEIGHT)
H	MJ x MJ TO FLANGE REDUCING C.I. TEE
I	3" BRONZE PIPE TO RUN BEHIND SIDEWALK, IF APPLICABLE
J	3" FLANGED 90° OR 3" x 4" FLANGED x FLANGED REDUCING 90° ELBOW AS REQUIRED
K	THRUST BLOCK (USE THRUST BLOCK SIZE FOR 4" PIPE, DWG. W-2)
L	PIPE CLAMP
M	CENTERING BLOCK (7.5" DIA 1 LB POWDER COATED)

NOTES:

1. FOR SIZE OF BLOW-OFF ON MAINS LARGER THAN 16", CONSULT DISTRICT ENGINEER.
2. COAT VALVE WITH BITUMINOUS PAINT, SEE SPECIFICATIONS.
3. RECYCLED WATER BLOW OFF ASSEMBLIES SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.
4. ALL BOLTS SHALL BE STAINLESS STEEL TYPE 304, OR APPROVED EQUAL. ANTI-SEIZE LUBRICANT SHALL BE APPLIED TO BOLT THREADS.

Dublin San Ramon Services District

REVISION DATE
NOV 2011

BLOW-OFF ASSEMBLY AT LOW POINT OF MAINS
6", 8", 10", 12" AND 14" MAINS

REVISED BY
BCD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-11