



NOTES

1. SECTION WITH NO. 600 CLAMP SHALL BE DUCTILE IRON WITH FLANGED ENDS.
2. DISTANCE SHALL NOT EXCEED 20 FT. AND NO SERVICE SHALL BE CONNECTED BETWEEN VALVE AND END OF WATER MAIN.
3. VALVES SHALL BE GATE VALVE FOR 6" TO 10" MAINS AND BUTTERFLY VALVES FOR 12" MAINS. VALVES SHALL HAVE RESILIANIT SEATS.
4. RECYCLED WATER BLOW OFF ASSEMBLIES SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.
5. USE 2" BLOWOFFS FOR 6" AND 8" MAINS: USE 4" BLOWOFFS FOR 10" MAINS: USE 6" BLOWOFFS FOR 12" MAINS.
6. CENTERING BLOCK (7.5" DIA 1 LB POWDER COATED).
7. ALL BOLTS SHALL BE STAINLESS STEEL TYPE 304, OR APPROVED EQUAL. ANTI-SEIZE LUBRICANT SHALL BE APPLIED TO BOLT THREADS.

Dublin San Ramon Services District

REVISION DATE
DEC 2011

TEMPORARY BLOWOFF FOR 12" MAINS AND SMALLER
WHEN VALVE IS NOT BOLTED TO TEE OR CROSS

DESIGNED
BCD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-12