



**NOTES:**

1. LENGTH OF EXTENSION IN INCHES SHALL BE INSCRIBED WITH AN ARC WELD BEAD (MIN. OF 2" IN HEIGHT) ON TOP FACE OF CIRCULAR PLATE.
2. VALVE KEY SHALL FIT OVER STANDARD 2" VALVE OPERATING NUT.
3. EXTENSION NUT AND VALVE KEY TO BE IN ALIGNMENT WITH EACH OTHER.

Dublin San Ramon Services District	REVISION DATE MAR 2012
VALVE NUT EXTENSION	REVISED BY BCD
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING W-4