



SERVICE WITH 90° TAP  
W/ POLYETHYLENE

ITEM	DESCRIPTION
A	CORPORATION STOP (MUELLER 300 SERIES, MCDONALD 74701 BQ, OR EQUAL)
B	COMPRESSION JOINT
C	POLYETHYLENE TUBING WITH COPPER WIRE (BLUE HDPE FOR POTABLE AND PURPLE HDPE FOR RECYCLED WATER)
D	ANGLE CURB STOP W/WING LOCK - BRONZE (MUELLER 300 SERIES, MCDONALD 74602 BT, OR EQUAL)
E	SERVICE SADDLE - BRONZE (ROCKWELL 323, MUELLER 16100, MCDONALD 3825, OR APPROVED EQUAL)
F	FACE OF CURB MARKED "W" FOR POTABLE WATER AND "RW" FOR RECYCLED WATER.

NOTES:

1. MINIMUM COVER FOR THE SERVICE LINE SHALL BE 36 INCHES.
2. SERVICE LINE SHALL REST ON UNDISTURBED EARTH.
3. STAINLESS STEEL INSERT STIFFENERS SHALL BE USED AT CORP. AND ANGLE STOPS IN POLYETHYLENE SERVICE LINES WHEN RECOMMENDED BY THE FITTING MANUFACTURER.
4. SEE DWG. W-19 FOR METER BOX INSTALLATION.
5. ANGLE CURB STOP SHALL BE 1"x1" MINIMUM.

Dublin San Ramon Services District

REVISION DATE  
NOV 2011

1" SERVICE INSTALLATION

REVISED BY  
BCD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING  
W-7