



SERVICE WITH 90° TAP

SERVICE ASSEMBLY

ITEM	DESCRIPTION
A	CORP. STOP – BRONZE (MUELLER 300 SERIES, MCDONALD 74701 BQ, OR EQUAL)
B	BRONZE COMPRESSION JOINT
C	POLYETHYLENE TUBING WITH TRACER WIRE
D	ANGLE CURB STOP, FLANGE W/WING LOCK – BRONZE (MUELLER 300 SERIES, MCDONALD 74602 BT, OR EQUAL)
E	ALL BRONZE SADDLE WITH DOUBLE STRAP (ROCKWELL 323, MUELLER 16100 SERIES, MCDONALD 3825)
F	FACE OF CURB TO BE MARKED "W" FOR POTABLE WATER AND "RW" FOR RECYCLED WATER.

NOTES:

1. THE SERVICE LINE SHALL REST ON UNDISTURBED EARTH IN THE BOTTOM OF THE TRENCH WITH A 36" MINIMUM COVER IN THE RUN BETWEEN THE MAIN AND THE CURB.
2. IRON SADDLES WILL NOT BE ALLOWED.
3. FOR METER BOX INSTALLATION SEE DWG W-19.
4. STAINLESS STEEL INSERT STIFFENERS SHALL BE USED AT CORP. AND ANGLE STOPS IN POLYETHYLENE SERVICE LINES WHEN RECOMMENDED BY THE FITTING MANUFACTURER.
5. POLYETHYLENE TUBING FOR POTABLE WATER SERVICE SHALL HAVE BLUE EXTERIOR.
5. POLYETHYLENE TUBING FOR RECYCLED WATER SERVICE SHALL HAVE PURPLE EXTERIOR.

Dublin San Ramon Services District

REVISION DATE
NOV 2011

1 1/2" – 2" SERVICE INSTALLATION

REVISED BY
BCD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-8