



ITEM	DESCRIPTION
A	2" FLG RESILIANIT SEATING G.V. WITH 2" SQ. NUT, CLOSE CLOCKWISE
B	SCREW FLANGE
C	2" BRONZE NIPPLE
D	TRACER WIRE FOR PVC PIPE ONLY, TW TYPE #10
E	2" BRONZE 90° ELL
F	2" BRONZE CLPG
G	2" BRONZE SCREW PLUG
H	2" BRONZE RISER (1 LENGTH TO PROPER HEIGHT)
I	C.I. CAP WITH 2" TAP
J	2" BRONZE PIPE
K	PIPE CLAMP
L	CENTERING BLOCK (7.5" DIA 1 LB POWDER COATED)

NOTES:

1. FOR SIZE OF BLOW-OFF ON MAINS LARGER THAN 16", CONSULT DISTRICT ENGINEER.
2. LOWER PORTION OF 2" PIPE AND G.V. TO BE BURIED IN CONCRETE THRUST BLOCK. DO NOT BURY BONNET OF G.V. WITH CONCRETE.
3. TO BE USED ONLY AT THE DIRECTION OF DISTRICT ENGINEER.
4. COAT VALVE WITH BITUMINOUS PAINT, SEE SPECIFICATIONS.
5. RECYCLED WATER BLOW OFF ASSEMBLIES SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES AS PER SPECIFICATION SECTION IV-B1-2.06.
6. ALL BOLTS SHALL BE STAINLESS STEEL TYPE 304, OR APPROVED EQUAL. ANTI-SEIZE LUBRICANT SHALL BE APPLIED TO BOLT THREADS.

Dublin San Ramon Services District

REVISION DATE
NOV 2011

2" BLOW-OFF ASSEMBLY AT DEAD END
6" AND 8" MAINS

REVISED BY
BCD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-9