



**NOTES:**

1. NO TAP TO BE MADE WITHIN 36" OF A JOINT OR FITTING.
2. CONTRACTOR TO INSTALL THRUST BLOCK BEHIND AND UNDER TAPPING SLEEVES.
3. TAPPING SLEEVE SHALL BE JCM 432 ALL STAINLESS STEEL TAPPING SLEEVE, MUELLER NO. H-615 (FOR CL SIZE OD PIPE), OR H-619 (FOR AC PIPE) OR EQUAL.

REV. 07/04

Dublin San Ramon Services District	DATE JUN 1997
EXCAVATION FOR TAPPING SLEEVES & VALVES	DESIGNED SB
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING W-17A