



NOTES:

1. SEE TO SECTION II-B2-10. METER BOXES, FOR METER BOX SCHEDULE
2. H2O TRAFFIC LOADING BOXES & LIDS TO BE USED IN TRAFFIC AREAS.
3. ALL METER BOXES MUST BE SET TRUE, PERPENDICULAR TO STREET, AND FLUSH WITH SIDEWALK.
4. SPACE BETWEEN BOXES IN MULTIPLE METER INSTALLATIONS SHALL BE 2".
5. DO NOT SET METER BOXES ON PRIVATE PROPERTY.
6. LID TO BE ONE PIECE, MARKED WATER, AND TOUCH-READ READY.
7. IN SLOPED AREA METER BOX MAY REQUIRE REDWOOD RETAINING BOARDS.
8. METER BOXES OUTSIDE TRAFFIC AREA SHALL BE CHRISTY FIBRELYTE BOX WITH FIBRELYTE LIDS, OR APPROVED EQUAL. METER BOXES IN TRAFFIC AREAS SHALL BE CHRISTY CONCRETE METER BOX WITH H-20 TRAFFIC RATED LIDS, OR APPROVED EQUAL. INSTALL 6" CONCRETE COLLAR AROUND THE METER BOX.
9. METER BOXES FOR RECYCLED WATER METERS, OR METERS WITH ASSOCIATED BACKFLOW PREVENTION DEVICES, SHALL HAVE A 6" CONCRETE COLLAR AROUND THE METER BOX.
10. RECYCLED WATER METER BOX INSTALLATION SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES PER SECTION IV-B1-2.04.

Dublin San Ramon Services District

METER BOX INSTALLATIONS
5/8 INCH TO 6 INCH

SIGNED COPY ON FILE AT DISTRICT OFFICE

REVISION DATE
NOV 2012

REVISED BY
BCD

DRAWING
W-19