



KEY	QTY	MATERIALS
A	1	JCM 432 ALL STAINLESS STEEL TAPPING SLEEVE, MEULLER NO. H-615, OR H-19, OR APPROVED EQUAL.
B	1	4" TAPPING GATE VALVE, FLANGE BY MJ
C	1	4" DIP OR PVC
D	1	4" FLANGED COUPLING ADAPTER
E	1	4"x4" DIP ELL, FLG. x FLG.
F	1	4" DIP SPOOL, FLG. x FLG.
G	1	4"x3" REDUCING DIP ELL, FLG. x FLG.
H	1	3" GATE VALVE, FLG. x FLG.
I	1	3"x3" FLANGE X MJ ADAPTER FLANGE
J	1	TW#10 TRACER WIRE, EXTEND INTO METER BOX

NOTES:

1. ALL THRUST BLOCKS TO BE POURED AGAINST UNDISTURBED SOIL.
2. SEE DRAWING W-19 FOR METER BOX INSTALLATION.

REV. 01/07

Dublin San Ramon Services District

DATE
MAY 1987

3" METER INSTALLATION

DESIGNED
BMD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-20