



KEY	QTY	MATERIALS
A	1	JCM 432 ALL STAINLESS STEEL TAPPING SLEEVE, MULLER NO. H-615, OR H-19, OR APPROVED EQUAL.
B	1	4" TAPPING GATE VALVE, FLANGE BY MJ
C	1	4" DIP OR PVC
D	1	4" FLANGED COUPLING ADAPTER
E	1	4"x4" DIP ELL, FLG. x FLG.
F	1	4" DIP SPOOL, FLG. x FLG.
G	1	4" ELL, FLG. x FLG.
H	1	2" BRASS NIPPLE
I	1	2" MUELLER 300 SERIES OR EQUAL
J	1	TW#10 TRACER WIRE, EXTEND INTO METER BOX

NOTES:

1. ALL THRUST BLOCKS TO BE POURED AGAINST UNDISTURBED SOIL.
2. SEE DRAWING W-19 FOR METER BOX INSTALLATION.

Dublin San Ramon Services District

REVISION DATE  
MAR 2012

4-INCH SERVICE W/ 2-INCH METER INSTALLATION

REVISED BY  
BCD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING  
W-20A