

Recycled Water Analysis

Name _____

Zone 7
Treatment Plants

Wells

Test	Drinking Water	Recycled Water
Turbidity	0.05 - 0.14 <small>NTU FAU</small>	0.2 - 2.0 <small>NTU FAU</small>
Total Dissolved Solids	212 - 420 <small>ppm</small>	568 - 689 <small>ppm</small>
Hardness	80 - 158 <small>ppm</small>	176 - 300 <small>ppm</small>
Ammonia	< 0.2 <small>ppm</small>	25.2 - 43.1 <small>ppm</small>
Nitrate	ND - 1.8 <small>ppm</small>	0.3 - 2.2 <small>ppm</small>
Nitrite	ND <small>ppm</small>	0.4 - 2.6 <small>ppm</small>

0.05 - 0.16
379 - 440
239 - 577
< 0.2
2.5 - 7.9
ND