



ALTERNATE ARRANGEMENT FOR LONG NUMERALS.

LETTERS **FACILITY**

BO	BLOW OFF
GV	GATE VALVE
AV	AIR VALVE

THE IDENTIFICATION FOR BY PASS VALVES SHALL CARRY THE ADDITIONAL LETTERS "BP"

WM	WATER MAIN
RW	RECYCLED WATER MAIN
SM	SEWER MAIN
LS	LATERAL SEWER
MH	MANHOLE
CO	CLEANOUTS

NOTES:

1. ROMAN NUMERALS REPRESENT THE DISTANCE TO THE NEAREST FOOT, MEASURED PERPENDICULAR, FROM THE FACE OF THE MARKER POST TO THE CENTER OF THE FACILITY.
2. ALL MARKER POSTS MUST BE SET TRUE, FACING THE FACILITY.
3. AVOID SETTING MARKER POSTS ON PRIVATE PROPERTY OR IN TRAVELED WAY.
4. MARKER POSTS ARE NOT REQUIRED WHERE REFERENCES CAN BE INCISED ON PERMANENT CURBS.
5. POST TO BE ASTM A53 SCH 40 STEEL FILLED WITH CONCRETE.
6. POSTS SHALL HAVE FACTORY APPLIED PRIMER COAT AND FIELD APPLIED EPOXY TOP COAT. TOP COAT SHALL BE WHITE WITH RED LETTERS AND NUMERALS.
7. MARKER POSTS FOR RECYCLED WATER SHALL BE AS PER NOTE 5, EXCEPT POSTS SHALL BE PAINTED PURPLE.
8. SEE DRAWING G-4A FOR ROMAN NUMERAL CHART.

REV. 04/07

Dublin San Ramon Services District	DATE DEC 2019
MARKER POST (4" x 4")	DESIGNED BD
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING G-4