



NOTES:

1. TO BE USED WHERE DISTANCE FROM TOP OF BASE TO BOTTOM OF COVER FRAME IS BETWEEN 15" AND 30".
2. MANHOLE SHALL HAVE NO STEPS.
3. JOINTS, IF USED, SHALL BE WRAPPED WITH 9-INCH RUB'R-NEK EXTERNAL CONCRETE JOINT WRAP, OR APPROVED EQUAL.

Dublin San Ramon Services District

DATE
DEC 2019

STANDARD SHALLOW MANHOLE

DESIGNED
BD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
S-4