



1. CONCRETE GREASE INTERCEPTOR SHALL BE AS LISTED ON THE APPROVED MATERIALS LIST, OR APPROVED EQUAL.
2. THE GREASE INTERCEPTOR SHALL BE LOCATED AND INSTALLED OUTSIDE OF THE BUILDING.
3. THE GREASE INTERCEPTOR SHALL BE LOCATED AND/OR CONSTRUCTED IN SUCH A MANNER AS TO EXCLUDE THE ENTRANCE OF SURFACE, STORM, OR RAINWATER.
4. SIZE OF GREASE INTERCEPTOR SHALL BE APPROVED BY THE DISTRICT ENGINEER.
5. BOX DESIGN LOAD IS H2O TRAFFIC LOADING WITH 1' TO 6' OF SOIL COVER.
6. ALL EXPOSED EXTERIOR COUPLINGS SHALL BE "NO-HUB" COUPLINGS ALL INTERIOR FITTINGS SHALL BE "NO-HUB" CAST IRON OR APPROVED EQUAL.
7. INSTALL SAMPLING BOX WITHIN 3' OF THE OUTLET OF THE GREASE INTERCEPTOR.
8. GREASE INTERCEPTOR SHALL BE SET ON DRAIN ROCK.

CAPACITY IN GALLONS	REFERENCE MODEL (JENSEN)	A	B	C	D	E	F
750	JP750EPE-G	5'-0"	4'-9"	6'-3"	4'-0"	8'-1"	4'-3"
1000	JP1000EPE-G	5'-0"	4'-9"	6'-3"	5'-1"	8'-2"	5'-4"
1200	JP1200EPE-G	5'-0"	4'-9"	6'-6"	5'-9"	8'-6"	6'-0"
1500	JP1500EPE-G	5'-0"	4'-9"	6'-3"	5'-7"	10'-8"	5'-10"

Dublin San Ramon Services District

REVISION DATE
DEC 2019

GREASE INTERCEPTOR
750 - 1500 GALLON CAPACITY

REVISED BY
BD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
S-13