



**VALVE BOX
WITH CAST IRON
TRAFFIC LID**

NOTES:

1. A.C. PAVEMENT TO COMPLY WITH STREET PAVEMENT REQUIREMENTS.
2. FOR VALVE BOXES INSTALLED IN NON-TRAFFIC AREAS, CONCRETE COLLAR SHALL BE EXTENDED TO FINISH GRADE. SLOPE COLLAR TO DRAIN AWAY FROM LID.
3. RISER PIPE TO BE ONE CONTINUOUS PIECE OF PVC.
4. VALVE BOX COVERS FOR RECYCLED WATER MAINS SHALL BE TRIANGULAR WITH "RW-DSRSD" INSCRIPTION CAST ON THE TOP SURFACE.
5. VALVE BOX COVERS FOR RW WATER MAINS SHALL BE POWDER COATED.

Dublin San Ramon Services District

REVISION DATE
JUN 2020

VALVE BOX INSTALLATION

REVISED BY
BD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-1