



NOTES:

1. VALVE NUT EXTENSION SHALL BE PROVIDED WHERE DEPTH TO TOP OF VALVE IS 4' OR MORE.
2. LENGTH OF EXTENSION IN INCHES SHALL BE INSCRIBED WITH AN ARC WELD BEAD (MIN. OF 2" IN HEIGHT) ON TOP FACE OF CIRCULAR PLATE.
3. VALVE KEY SHALL FIT OVER STANDARD 2" VALVE OPERATING NUT.
4. EXTENSION NUT AND VALVE KEY TO BE IN ALIGNMENT WITH EACH OTHER.

Dublin San Ramon Services District

REVISION DATE
DEC 2019

VALVE NUT EXTENSION

REVISED BY
KP

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-4