



SERVICE WITH 90° TAP
W/ POLYETHYLENE

ITEM	DESCRIPTION
A	BRONZE CORPORATION STOP
B	BRONZE COMPRESSION JOINT
C	POLYETHYLENE TUBING WITH TRACER WIRE (BLUE HDPE FOR POTABLE AND PURPLE HDPE FOR RECYCLED WATER)
D	BRONZE ANGLE CURB STOP W/WING LOCK
E	BRONZE SERVICE SADDLE PER SECTION II-B1-2.08
F	FACE OF CURB MARKED "W" FOR POTABLE WATER AND "RW" FOR RECYCLED WATER.

- NOTES:
1. THE SERVICE LINE SHALL REST ON UNDISTURBED EARTH IN THE BOTTOM OF THE TRENCH WITH A 36" MINIMUM COVER IN THE RUN BETWEEN THE MAIN AND THE CURB.
 2. FOR METER BOX INSTALLATION SEE DWG W-19.
 3. STAINLESS STEEL INSERT STIFFENERS SHALL BE USED AT CORP. AND ANGLE STOPS IN POLYETHYLENE SERVICE LINES WHEN RECOMMENDED BY THE FITTING MANUFACTURER.
 4. COLOR OF POLYETHYLENE TUBING SHALL BE:
BLUE FOR POTABLE WATER SERVICE
PURPLE FOR RECYCLED WATER SERVICE

Dublin San Ramon Services District	REVISION DATE NOV 2019
1" SERVICE INSTALLATION	REVISED BY KP
SIGNED COPY ON FILE AT DISTRICT OFFICE	DRAWING W-7