



NOTES:

1. SEE THE APPROVED MATERIAL LIST FOR METER BOX SCHEDULE
2. H20 TRAFFIC LOAD RATED BOXES & LIDS TO BE USED IN TRAFFIC AREAS.
3. ALL METER BOXES MUST BE SET TRUE, PERPENDICULAR TO STREET, AND FLUSH WITH SIDEWALK.
4. SPACE BETWEEN BOXES IN MULTIPLE METER INSTALLATIONS SHALL BE 2".
5. DO NOT SET METER BOXES ON PRIVATE PROPERTY.
6. LID TO BE ONE PIECE, MARKED WATER, AND TOUCH-READ READY WITH 2" PROBE HOLE.
7. IN SLOPED AREA METER BOX MAY REQUIRE REDWOOD RETAINING WALLS.
8. METER BOXES AND LIDS IN TRAFFIC AREAS SHALL BE H-20 TRAFFIC RATED. INSTALL 6" CONCRETE COLLAR (6" DEEP) AROUND TRAFFIC-RATED METER BOXES.
9. METER BOXES OUTSIDE OF TRAFFIC AREAS AND NOT IN SIDEWALK SHALL HAVE 6" WIDE COLLAR (4" DEEP).
10. RECYCLED WATER METER BOX INSTALLATION SHALL BE IDENTIFIED AS RECYCLED WATER FACILITIES PER SECTION IV-B1-2.04.

Dublin San Ramon Services District

REVISION DATE
NOV 2019

METER BOX INSTALLATIONS
5/8 INCH TO 2 INCH

REVISED BY
KP

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING
W-19