



KEY	QTY	MATERIALS
A	1	4" GATE VALVE, FLANGE BY RESTRAINED MJ PER SECTION II-B1-2.02
B	1	4" DIP OR PVC
C	1	4" FLANGED COUPLING ADAPTER
D	1	4"x4" DIP ELL, FLG. x RESTRAINED MJ
E	1	4" DIP SPOOL, FLG. x FLG.
F	1	4"x4" DIP ELL, FLG. x FLG.
G	1	TW#10 TRACER WIRE, EXTEND INTO VALVE BOX

NOTES:

1. ALL THRUST BLOCKS SHALL CONFORM TO STANDARD DRAWINGS W-2 AND W-3.
2. ALL BOLTS SHALL BE STAINLESS STEEL TYPE 316, ANTI-SEIZE LUBRICANT SHALL BE APPLIED TO BOLT THREADS. POLYWRAP ALL FERROUS PIPE AND FITTINGS.
3. METER TO BE INSTALLED BY DSRSD.

Dublin San Ramon Services District

REVISION DATE  
JAN 2021

3" METER INSTALLATION

REVISED BY  
RM

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING  
W-20