



NOTES:

1. RECYCLED WATER NOTIFICATION SIGN POST TO BE PROVIDED BY DEVELOPER.
2. POST SHALL BE 2" DIAMETER GALVANIZED STEEL.
3. FOOTING SHALL BE 24' IN DEPTH, IN CONCRETE.

Dublin San Ramon Services District

REVISION DATE  
JUN 2020

RECYCLED WATER SIGN POST DETAIL

REVISED BY  
KP/BD

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING  
W-28