



NOTES:

1. ALL SERVICE CONNECTIONS (EXCEPT FIRE SERVICE CONNECTIONS) SHALL BE MADE DOWNSTREAM OF THE RESTRICTION IN THE DOMESTIC SERVICE LINE.
2. THE ONE-HALF INCH RESTRICTOR AND BOTH TEES SHOWN ON THIS DRAWINGS SHALL BE ON THE OUTSIDE OF THE HOUSE AND SHALL BE VISIBLE FROM THE STREET UNLESS A LETTER OF EXEMPTION IS ON FILE WITH DSRSD.
3. SIZES OF PIPING MAY VARY PER PLANS. SIZE OF RESTRICTOR SHALL ALWAYS BE ONE-HALF (1/2) INCH.
4. MATERIAL SHALL CONFORM TO THE LATEST UNIFORM PLUMBING CODE.
5. INSTALLATION OF A HOSE BIB AT THE EXTERIOR OF THE HOME IS PERMISSIBLE.

SCALE: N.T.S.

Dublin San Ramon Services District

REVISION DATE
MAY 2022

OUTDOOR PLUMBING SCHEMATIC (SINGLE FAMILY RESIDENTIAL ONLY)

REVISED BY
RM

SIGNED COPY ON FILE AT DISTRICT OFFICE

DRAWING

W-33